

**SIX MONTHS / REERECTION / YEARLY SAFETY CHECK-LIST FOR THE PASSENGER HOISTS**



Site Name:		<b>Statutory Inspection is due on:</b>			
Machine Sr.No:		Date of Inspection			
Sr. No.	Activity				
	Fail safe brake testing and all other safety aspects of lift	Six month / re-erection which ever is earlier			
1	Third party inspection	Yearly or re-erection which ever is earlier			
Name & Sign. Of lift Operator		Name Signature of the Engineer - P&M	Signature of the Engineer - Electrical - Verified		
<p><b>Safety Instructions for Passenger Hoists:</b>                  Above points to be read with operational manual for further detail.                  All the tolerances and dimensions need to be varified as per the figures mentioned in Manual and to replced if observed beyond acceptable limits                  Maximum allowable testing of Safety device is 3 nos only.</p>					